

"Cleveland County
Grows Greater"



P.O. BOX 1210 SHELBY, NORTH CAROLINA 28150

OFFICE OF COUNTY BUILDING INSPECTOR

TEMPORARY POWER

The code enforcement official shall give permission and issue a permit to energize the electrical service when the provisions of 10.8 and the following requirements have been met:

- 1) The service wiring and equipment, including the meter socket enclosure, shall be installed, the service wiring terminated, and the service equipment covers installed.
- 2) The portions of the electrical system that are to be energized shall be complete and physically protected.
- 3) The grounding electrode system shall be complete.
- 4) The grounding and grounded conductors shall be terminated in the service equipment.
- 5) At least one receptacle outlet with ground fault circuit interrupter protection for personnel shall be installed with the circuit wiring terminated.
- 6) The applicable requirements of the North Carolina Electrical Code shall apply.

In no case shall any portion of the permanent wiring be energized until the portions have been inspected and approved by an Electrical Code Enforcement Official. Failure to comply with this section may result in disconnection of power or revocation of permit.

Application for temporary power shall be made by and in the name of the applicant. The application shall explicitly state the portions of the energized electrical system, mechanical system, or plumbing system for which application is made, its intended use and duration.

The applicant shall maintain the energized electrical system or that portion of the building containing the energized electrical system in a secured and locked manner or under constant supervision to exclude unauthorized personnel. **The applicant shall assume the responsibility to alert personnel working in the vicinity of the energized electrical system to its presence.**

ADDRESS: _____
PORTIONS TO BE ENERGIZED: _____
INTENDED USE: _____
DURATION: _____

Signature of applicant

Date

Signature of Electrician

Date

FAX BACK TO: 704-484-4903